



- NOTES:
- 1043 GALLONS/VERTICAL FOOT CAPACITY.
 - WIDE FLANGE INSTALLATION BY CONTRACTOR
 - 4" - 6" KOR N SEAL BOOTS @ INLET/OUTLET PENETRATIONS.

REBAR:

WALLS: #6 @ 6" O.C. HORIZONTAL
 #4 @ 10" O.C. VERTICAL

TOP & BOTTOM: #6 @ 6" O.C. SHORT DIRECTION
 #4 @ 10" O.C. LONG DIRECTION

WEIGHTS/SECTION:

TOP: 19097#
 WALL: 4575# PER VERTICAL FOOT
 BOTTOM: 19097#

H-20 TRAFFIC BEARING
 NO SUBSURFACE WATER PRESENT
 (WILBERT PRECAST PRODUCT # 916 3000 S/OW
 - HEAVY LOAD OPTION OR APPROVED EQUIVALENT)

CITY OF LEWISTON, IDAHO PUBLIC WORKS DEPARTMENT	
3000 GALLON SAND OIL/WATER SEPARATOR	
APPROVED FOR PUBLICATION <i>Shawn Stubbins</i> 6/2/10 City Engineer	DWG. NO. I-10
Date	